

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/25/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 03 B. WING _____		(X3) DATE SURVEY COMPLETED C 02/18/2015
NAME OF PROVIDER OR SUPPLIER GARDEN VILLA - BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 1100 S CURRY PK BLOOMINGTON, IN 47403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>An investigation of Complaint Number IN00165306 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Complaint Number IN00165306 Substantiated, No deficiencies related to the allegation are cited.</p> <p>Date of Survey: 02/18/15</p> <p>Facility Number: 000007 Provider Number: 155019 AIM Number: 100275040</p> <p>Surveyor: Dennis Austill, Life Safety Code Specialist</p> <p>Census: 174</p> <p>At this Complaint survey, Garden Villa - Bloomington was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has battery operated smoke detectors installed in resident sleeping rooms 101 through 126, 201 through 216 and 301 through 339. The facility</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/25/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 03 B. WING _____		(X3) DATE SURVEY COMPLETED C 02/18/2015
NAME OF PROVIDER OR SUPPLIER GARDEN VILLA - BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 1100 S CURRY PK BLOOMINGTON, IN 47403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 has smoke detectors hard wired to the fire alarm system in resident sleeping rooms on Unit 4, 5, and 6. The facility has a capacity of 224 and had a census of 174 at the time of this survey.	K 000			
K 000	Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 02/19/15. INITIAL COMMENTS An investigation of Complaint Number IN00165306 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Complaint Number IN00165306 Substantiated, No deficiencies related to the allegation are cited. Date of Survey: 02/18/15 Facility Number: 000007 Provider Number: 155019 AIM Number: 100275040 Surveyor: Dennis Austill, Life Safety Code Specialist Census: 174 At this Complaint survey, Garden Villa - Bloomington was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2.	K 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/25/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 03 B. WING _____		(X3) DATE SURVEY COMPLETED C 02/18/2015
NAME OF PROVIDER OR SUPPLIER GARDEN VILLA - BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 1100 S CURRY PK BLOOMINGTON, IN 47403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 2</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has battery operated smoke detectors installed in resident sleeping rooms 101 through 126, 201 through 216 and 301 through 339. The facility has smoke detectors hard wired to the fire alarm system in resident sleeping rooms on Unit 4, 5, and 6. The facility has a capacity of 224 and had a census of 174 at the time of this survey.</p> <p>Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 02/19/15.</p>	K 000			